

VALINTATAULUKKO

Tilavuusvirta, qv (m³/s) imurissa läpivientiosa paikoillaan | Staattinen paine-ero (Pa)

qv (m ³ /s)	50	75	100	125	150	175	200	225	250	300	350	400	500	600	800
15P-EC, 15P-ECH	0,155	0,150	0,145	0,140	0,135	0,130	0,120	0,110	0,105	0,090	0,075	0,060	0,030		
20P-EC, 20P-ECH	0,192	0,185	0,180	0,170	0,157	0,145	0,135	0,122	0,115	0,082	0,055				
23P-EC, 23P-ECH	0,389	0,375	0,363	0,347	0,335	0,328	0,293	0,270	0,254	0,221	0,190	0,165	0,125		
25P-EC, 25P-ECH	0,705	0,700	0,690	0,685	0,680	0,670	0,660	0,650	0,640	0,620	0,600	0,580	0,540	0,480	0,260
31P-EC, 31P-ECH	0,810	0,785	0,775	0,760	0,740	0,720	0,700	0,680	0,660	0,615	0,560	0,500	0,270		
40P-EC, 40P-ECH	1,320	1,300	1,260	1,240	1,220	1,180	1,160	1,150	1,100	1,040	0,970	0,900	0,650		
50P-EC, 50P-ECH	2,050	2,020	1,970	1,950	1,910	1,870	1,830	1,800	1,750	1,670	1,580	1,480	1,200	0,750	
56P-EC, 56P-ECH	2,530	2,500	2,450	2,400	2,350	2,300	2,250	2,230	2,180	2,080	1,950	1,850	1,450	0,700	