

Product Conformity

**according to DIN EN 15632-1:2022-08, DIN EN 15632-2:2022-08 and
DIN EN 253:2020-03 on the preinsulated flexible pipe system**

„CALPEX PUR-KING“

Manufacturer:	BRUGG Rohrsystem AG
Production site:	Industriestr. 39 CH-5314 Kleindöttingen SWITZERLAND
Specimens:	Preinsulated flexible pipe systems CALPEX PUR-KING DN 63/126 mm Service pipe: PEX Insulation: PUR Casing: LLDPE
Delivery of samples:	2024-03-29, Sampling by customer
Test report numbers:	V315/24, V508/24
Tested characteristics:	Resistance to external loads Compressive creep Water absorption Foam density Axial shear strength Linear water tightness Closed cell content Thermal conductivity
Test result:	The preinsulated flexible pipe systems with PUR foam insulation fulfilled the requirements of DIN EN 15632-1, DIN EN 15632-2 and DIN EN 253 with the tested characteristics.

IMA Materialforschung und Anwendungstechnik GmbH

Wilhelmine-Reichard-Ring 4
01109 Dresden

Dresden, 2024-10-10

Place, Date



Patrick Langner
M. Eng. Patrick Langner

Deputy Head of Department
Pipe Systems and
Construction Products

Recognised test laboratory of Euroheat & Power
EHP001 – Straight Pipes / EHP003 – Steel Valves Certification Bodies and Test Institutes
The recognitions are valid for the test methods stated in the attachments of certificates of approval.