

CERTIFICATE

15632 2411 22A

according to EN 15632-1:2022 & EN 15632-4:2022

for

pre-insulated flexible bonded pipe system
with corrugated stainless steel service pipe:

CASAFLEX

by order of

BRUGG Rohrsysteme GmbH

This certificate is based on report 1853_5544 from 2024-11-14.

CASAFLEX meets requirements given in EN 15632-1:2022 5.1 Thermal insulation properties, 5.4.2 Thermal insulation, Water absorption at elevated temperatures, 5.4.3 Thermal insulation, Density of thermal insulation, 5.6 Surveillance systems and EN 15632-4:2022 6.4 Linear water tightness of pipe assemblies

Hemmingen, 2024-11-14



Thomas Grage
Managing director



FFI FERNWÄRME
FORSCHUNGSINSTITUT
GmbH

Max-von-Laue-Str. 23
30966 Hemmingen
+49 511 94370 0
www.fernwaerme.de



Sönke Kraft
Project manager